



# Certificate of Compliance

This certificate is issued for the following:

## Pipe Hanger Components for Automatic Sprinkler Systems

| <i>Product Designation</i> | <i>Hanger Rod Size, in. (mm)</i> | <i>Component Description</i> | <i>For Nominal Pipe Sizes, in.</i>   | <i>Remarks</i> |
|----------------------------|----------------------------------|------------------------------|--------------------------------------|----------------|
| SH                         | 3/8 (10)                         | Loop Hanger                  | 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4 | -              |
| SH                         | 1/2 (12)                         | Loop Hanger                  | 5, 6, 8                              | -              |

### Prepared for:

Tembo Global Industries Ltd  
Plot No. 146/147 MIDC – Turbhe -  
TTC, Navi Mumbai,  
Maharashtra 400703,  
India

### Manufactured by:

Tembo Global Industries Ltd  
Unit No. 1/B – Badrinath, Ground Floor,  
Tungareshwar Industrial Complex Sativali Village,  
Vasai (East), Dist. Thane, Maharashtra 401208  
India

FM Approvals Class: 1951, 1952, 1953 Issue Date December 2016

Approval Identification: 3056409

Superseded by: RR223825

Approval Granted: April 25, 2016

Date Approved: June 15, 2020

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D. B. Fuller', is written over a horizontal line.

David B. Fuller

VP, Manager of Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA



Member of the FM Global Group



# Certificate of Compliance

This certificate is issued for the following:

## Pipe Hanger Components for Automatic Sprinkler Systems

| <i>Product Designation</i> | <i>Hanger Rod Size, in. (mm)</i> | <i>Component Description</i> | <i>For Nominal Pipe Sizes, in.</i> | <i>Remarks</i> |
|----------------------------|----------------------------------|------------------------------|------------------------------------|----------------|
| CH                         | 3/8 (10)                         | Clevis Hanger                | 3/4, 1, 1-1/4, 1-1/2               | -              |
| CH                         | 1/2 (12)                         | Clevis Hanger                | 2-1/2, 3, 4                        | -              |
| CH                         | 5/8 (16)                         | Clevis Hanger                | 5, 6, 8                            | -              |

### Prepared for:

Tembo Global Industries Ltd  
Plot No. 146/147 MIDC – Turbhe -  
TTC, Navi Mumbai,  
Maharashtra 400703,  
India

### Manufactured by:

Tembo Global Industries Ltd  
Unit No. 1/B – Badrinath, Ground Floor,  
Tungareshwar Industrial Complex Sativali Village,  
Vasai (East), Dist. Thane, Maharashtra 401208,  
India

FM Approvals Class: 1951, 1952, 1953 Issue Date December 2016

Approval Identification: 3056409  
Superseded by: RR223825

Approval Granted: April 25, 2016  
Date Approved: June 15, 2020

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D. B. Fuller', is written over a horizontal line.

David B. Fuller  
VP, Manager of Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062 USA



Member of the FM Global Group